


## Declaration of Performance

DOP/CE/9008

**Bulk Water Meter Chamber STD-W-26**  
**Ballinamere, Tullamore, Co. Offaly**



- 1. Unique Identification code of the product - type:** Code – 9008 – Bulk Water Meter Chamber STD-W-26
- 2. Intended use:** Reinforced Precast Component with installed single steps for use as an inspection Meter Chamber
- 3. Manufacturer:** Creative Concrete, Ballinamere, Tullamore, Co. Offaly
- 4. Authorised Representative:** N/A
- 5. System of AVCP:** System 4
- 6. Harmonised Standard:** EN 1917:2002&AC:2008 **Notified body:** N/A

**7. Declared Performance**

Characteristic	Declared Performance	Provisions to Annex ZA (informative) of I.S EN 1917:2002
<b>Watertightness:</b>	No Leakage of joint or unit at 30kPa (0,3 bar) internally	4.3.8
<b>Mechanical resistance:</b>	Vertical Strength 400kN	4.3.5
<b>Opening Size:</b>	(LN x WN) 1200mm, 1200mm Square	4.3.3.5
<b>Durability:</b>	Adequate for normal serviceability conditions	4.3.10
<b>Load bearing capacity of installed steps:</b>	- Deflection $\leq$ 5mm under 2 kN Vertical load, with permanent deflection $\leq$ 1mm - Resistant to 5 kN horizontal pull-out force	4.3.7

8. N/A

<https://creativeconcrete.ie>

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

**Chris O'Reilly, Technical & Production Manager, Creative Concrete, Ballinamere, Tullamore, Co. Offaly**

**Date: 07th October 2022**


CE

Creative Concrete

22

**EN 1917:2002&AC:2008**  
**Bulk Water Meter Chamber STD-W-26**  
**(LxWxH) 1600mm, 1600mm, 1300mm**

1. **Unique Identification code of the product - type:** Code – 9008 – Bulk Water Meter Chamber STD-W-26
  2. **Intended use:** Reinforced Precast Component with installed single steps for use as an inspection Meter Chamber
  3. **Manufacturer:** Creative Concrete, Ballinamere, Tullamore, Co. Offaly
  4. **Authorised Representative:** N/A
  5. **System of AVCP:** System 4
  6. **Harmonised Standard:** EN 1917:2002&AC:2008 **Notified body:** N/A
- |   |                         |  |
|---|-------------------------|--|
| <b>Watertightness</b>                           | Declared Value          | No Leakage of joint or unit at 30kPa (0,3) bar) internally   |
| <b>Mechanical Resistance</b>                    | Declared Value          | Vertical Strength 400kN  |
| <b>Opening Size</b>                             | Declared Characteristic | (LN x WN) 1200mm, 1200mm Square  |
| <b>Durability</b>                               | Declared Performance    | Adequate for normal serviceability conditions  |
| <b>Load bearing capacity of installed steps</b> | Declared Performance    | - Defection $\leq$ 5mm under 2 kN Vertical load, with permanent deflection $\leq$ 1mm<br>- Resistant to 5 kN horizontal pull-out force |



Signed for and on behalf of the manufacturer by:

**Chris O'Reilly, Technical & Production Manager, Creative Concrete, Ballinamere, Tullamore, Co. Offaly**

**Date: 07<sup>th</sup> October 2022**