



Creative Concrete: Declaration of Performance of CE Marking of Product as specified hereunder.



17

Name and address of manufacturer.	Creative Concrete Ballinamere Tullamore Co Offaly
Contact details.	Telephone: +353 5793 55808 www.creativeconcrete.ie
Authorised representative.	None.
Harmonised standard.	IS EN 1917: 2004
Attestation of conformity system as per Table ZA.2. IS EN 1917: 2004	4.
Product description.	Reinforced concrete inspection chambers and junction boxes without fitted steps. Values stated in this certificate are the minimum values for the applicable product range.
Product Type	Eir JB4A Length: 890mm. Width: 910mm. Height: 800mm. Reinforced Concrete.
Concrete class.	C32/40 as per EN: 206-1: 2013
Notified body.	None.

Declared performance.

Provisions to which product conforms.	Annex ZA of IS EN 1917: 2004
Essential Characteristics.	
Opening size.	
Mechanical resistance as determined by testing in accordance with Annex A Clause A5 IS EN 1917: 2004.	Chamber Crushing Strength: 120 kn. Vertical Strength: 150kn. Compressive strength of concrete @ 28 days. Not less than 40Kn/mm ²
Load bearing capacity of fitted steps.	Not applicable. No steps fitted to product range.
Water tightness. IS EN 1917: 2004 Clause 4.3.8.	No leaks observed.
Durability.	Compressive strength of concrete 40Kn/mm ² . Suitable for use under normal conditions.

Declaration.

The performance of the product identified above is in conformance with the declared values when used for the purposes and in the conditions/circumstances for which it is intended, subject to installation in accordance with manufacturer's instructions.

Vincent Molloy

Signed: _____

Vincent Molloy

Managing Director.

Dated: 1st October 2019